

## CMG-40T-1 CALIBRATION SHEET

WORKS ORDER: 2968 DATE: 06-Oct-2005

SERIAL No: T4J62 TESTED BY: P. Stott

	Velocity Output V/m/s (Differential)	Mass Position Output (Acceleration output) V/m/s <sup>2</sup>	Feedback Coil Constant Amp/m/s <sup>2</sup>
VERTICAL	2 x 999.0	18.9	0.004028
NORTH/SOUTH	2 x 995.6	18.9	0.004017
EAST/WEST	2 x 994.8	18.2	0.003874

Power Consumption: 52.3mA @ +12V input  
Calibration Resistor: 51000

NOTE: A factor of 2 x must be used when the sensor outputs are used differentially (also known as push-pull or balanced output). Under no conditions should the negative outputs be connected to the signal ground. A separate signal ground pin is provided.

## POLES AND ZEROS TABLE

**WORKS ORDER No: 2968**

**SENSOR SERIAL No: T4J62**

Velocity response output, Vertical Sensor:

<u>POLES (HZ)</u>	<u>ZEROS HZ</u>
$-707.0 \times 10^{-3} \pm j 707.0 \times 10^{-3}$	0
$-62.3816 \pm j135.392$	0
-350	
-75	

Normalizing factor at 1 Hz: A =  $585.8 \times 10^6$

Sensor Sensitivity: See Calibration Sheet.

Velocity response output, Horizontal Sensors:

<u>POLES (HZ)</u>	<u>ZEROS (HZ)</u>
$-707.0 \times 10^{-3} \pm j 707.0 \times 10^{-3}$	0
$-62.3816 \pm j135.392$	0
-350	
-75	

Normalizing factor at 1 Hz: A =  $585.8 \times 10^6$

Sensor Sensitivity: See Calibration Sheet.

**NOTE:** The above poles and zeros apply to the vertical and the horizontal sensors and are given in units of Hz. To convert to Radian/sec multiply each pole or zero with  $2\pi$ . The normalizing factor A should also be recalculated.